



Town of South Kingstown, RI

Department of Public Services

509 Commodore Perry Highway

Wakefield, RI 02879

Tel: (401) 789-9331

Fax: (401) 782-8068

SEWER SERVICE ENGINEERING REVIEW REQUEST

Review Requested By: Jonnycake Center

Property Address: 12 Green Street

Plat: 49-1 148 Road Status: Town Private State

SEWER SERVICE IS AVAILABLE AT THIS TIME* (See Note)

SEWER SERVICE IS AVAILABLE AT THIS TIME, BUT REQUIRES
LATERAL INSTALLATION AT PROPERTY OWNER'S EXPENSE


SEWER SERVICE IS NOT AVAILABLE AT THIS TIME

SEWER MAIN EXTENSION REQUIRED

GREASE TRAP REQUIRED; CONTACT KRYSTAL FURLONG, PRETREATMENT
COORDINATOR, AT 788-9771 FOR MORE INFORMATION.

UTILITIES IN A STATE RIGHT-OF-WAY WILL REQUIRE A RIDOT INSPECTION.
APPLICANT SUBJECT TO PAY ALL RIDOT INSPECTION FEES.

OTHER: As proposed, use existing lateral. Clean check valve
required at building per Town requirement. Work with
sewer dept. when ready to construct.


RICHARD J BOURBONNAIS, PE, Public Services Director
KATHY PEREZ, Wastewater Superintendent

12-6-2023
DATE

***NOTE:** The Town makes no warranty either written or implied as to the accuracy of lateral installation.
Confirmation of lateral is only warranted upon test-pit verification at property owner's expense.