



**Patrick Grant, Superintendent**  
**Veolia Water Rhode Island**  
**10 High Street, Suite K**  
**Wakefield, RI 02879**  
**TEL 401-228-5912**

**June 12, 2025**

**Re: Saugatucket Acres - 176 Saugatucket Road, South Kingstown, RI 02879**

This letter is to inform you that water service is available at the above referenced proposed five-lot subdivision located in **South Kingstown, Rhode Island** using a projected max daily demand of **2,300 GPD** from the Veolia Water Rhode Island (VWRI) system. Will be subject to the following conditions: Items 1 and 2 shown below are approved. It is understood that the service tap and line will be installed subject to final inspection by Veolia. Due to distance restrictions, Home lots 2,3, and 4 will require the installation of meter pits within 10 feet of the Utility ROW.

- 1) Prior to the installation of any services or the extension of any mains, hydraulic data pertinent to the project must be provided to us for our Engineering Department review and approval.
- 2) If, as a result of such review it is decided that any extension of mains or pipes or modification of other facilities is required in order to meet the hydraulic needs of the project, those mains or facilities will be installed or extended by you in accordance with the terms and conditions of this Company's standard agreements for extensions.
- 3) Service will be provided in accordance with the terms and conditions set forth in the Company's filed Tariff, as amended or modified from time to time.
- 4) Water mains shall be laid in accordance with the Recommended Standards for Water Works (a.k.a. Ten State Standards).

This Willingness to Serve letter is contingent upon Veolia Water Rhode Island having County, State and Federal regulatory authority to provide the requested water service and is valid for nine (9) months from the date of issuance. If the main/extension or service installation is not completed and approved by Veolia Water Rhode Island within the nine (9) months from the date this letter is issued, this Willingness to Serve letter will expire, and it will be necessary for you to request a new willingness to serve letter.

Please contact me at 401-228-5912 or Michael McManus, Planning Coordinator at (401) 287-2338 if you need additional information.

Respectfully,  
Patrick Grant, Superintendent

A handwritten signature in black ink, appearing to read "Patrick Grant", written over a light blue horizontal line.