



WATER • WASTEWATER • STORMWATER
SOLUTIONS

38 Albion Rd, Lincoln RI

Customer name and address:
DiPrete Engineering Associates
2 Stafford Ct.
Cranston, RI 02920

Date: 5.17.24

Hydrant : 1

Next hydrant west bound on Saugatucket Rd

Static psi: 76 PSI while hyd 2 in flow 70

Hydrant 2

176 Saugatucket Rd S. Kingstown RI

By farm entrance

GPM	PSI
1300	60