

AMERICAN ENGINEERING, INC.

400 South County Trail – Suite A 201 Exeter, RI 02822
(401) 294-4090

September 9, 2025

Town of South Kingstown
180 High Street
Wakefield, RI 02879


RE: Application of Keystone, LLC. locate at A.P. 57-1, Lot 73 – 82 Main Street in South Kingstown, Rhode Island

To Whom It May Concern:

This letter is written to address the proposed daily wastewater flow for the proposed development located at 82 Main Street in South Kingstown, Rhode Island. The daily sewer flow will be approximated using the RIDEM Design Wastewater Flows per 250-RICR-150-10-6.22. The proposed mixed-use building will have three 2-bedroom residential units and 5 employees. RIDEM states that 115 gallons per day of wastewater is produced per bedroom and 15 gallons per day of wastewater are produced per employee. Per these values, the daily wastewater flow produced by the development is 765 gallons per day.

If there are any questions or if we can be of any further assistance to you either now or in the future, please call.

Yours Truly,



Patrick J. Freeman, PE