



Town of South Kingstown, RI

Department of Public Services

509 Commodore Perry Highway

Wakefield, RI 02879

Tel: (401) 789-9331

Fax: (401) 782-8068

SEWER SERVICE ENGINEERING REVIEW REQUEST

Review Requested By: **Kathleen Salisbury**

Property Address: **23 Rockland Drive**

Plat: **56-2** **7** Road Status: Town Private State

- SEWER SERVICE IS AVAILABLE AT THIS TIME* (See Note)
- SEWER SERVICE IS AVAILABLE AT THIS TIME, BUT REQUIRES LATERAL INSTALLATION AT PROPERTY OWNER'S EXPENSE
- SEWER SERVICE IS NOT AVAILABLE AT THIS TIME
- SEWER MAIN EXTENSION REQUIRED
- GREASE TRAP REQUIRED; CONTACT KRYSTAL FURLONG, PRETREATMENT COORDINATOR, AT 788-9771 FOR MORE INFORMATION.
- UTILITIES IN A STATE RIGHT-OF-WAY WILL REQUIRE A RIDOT INSPECTION. APPLICANT SUBJECT TO PAY ALL RIDOT INSPECTION FEES.
- OTHER:**
Sewer work to be performed by a RI Licensed Underground Utility Contractor. Sewer line available along Rockland Drive. Two sewer laterals must be installed to each proposed dwelling off Rockland Drive.

Install a Sewer Cleanout at Property line. Install a Sewer Clean Check Valve within 5 feet of face of foundation. Maintain 10' minimum horizontal separation between water and sewer services. Payment of applicable fees for each new proposed lot. Existing dwelling, 23 Rockland Drive, will remain on O WTS.

RICHARD J BOURBONNAIS, PE, Public Services Director
KATHY PEREZ, Wastewater Superintendent

DATE

***NOTE:** The Town makes no warranty either written or implied as to the accuracy of lateral installation. Confirmation of lateral is only warranted upon test-pit verification at property owner's expense.

11/12/25