



# Town of South Kingstown, RI

Department of Public Services

509 Commodore Perry Highway

Wakefield, RI 02879

Tel: (401) 789-9331

Fax: (401) 782-8068

## SEWER SERVICE ENGINEERING REVIEW REQUEST


Review Requested By: Adam Drake

Property Address: 2001 Kingstown Road

Plat: 32-4                      21                      Road Status:  Town  Private  State

- SEWER SERVICE IS AVAILABLE AT THIS TIME\* (See Note)
- SEWER SERVICE IS AVAILABLE AT THIS TIME, BUT REQUIRES LATERAL INSTALLATION AT PROPERTY OWNER'S EXPENSE
- SEWER SERVICE IS NOT AVAILABLE AT THIS TIME
- SEWER MAIN EXTENSION REQUIRED
- GREASE TRAP REQUIRED; CONTACT KRYSTAL FURLONG, PRETREATMENT COORDINATOR, AT 788-9771 FOR MORE INFORMATION.
- UTILITIES IN A STATE RIGHT-OF-WAY WILL REQUIRE A RIDOT INSPECTION. APPLICANT SUBJECT TO PAY ALL RIDOT INSPECTION FEES.
- OTHER:

Sewer work to be performed by a RI Licensed Underground Utility Contractor. A RI Professional Engineer will need to complete a carrying capacity analysis for the sewer later to make sure is is of sufficient capacity to accommodate the proposed additional wastewater flow. Maintain 10' minimum horizontal separation between water and sewer services. Payment of applicable fees for each new proposed lot.

  
\_\_\_\_\_  
RICHARD J. BOURBONNAIS, PE, Public Services Director  
RYAN DESROSIERS, Wastewater Superintendent

12/16/25  
\_\_\_\_\_  
DATE

**\*NOTE:** The Town makes no warranty either written or implied as to the accuracy of lateral installation. Confirmation of lateral is only warranted upon test-pit verification at property owner's expense.

12/16/25